

Online Drinking Water Notifications

Local authority: Wexford County Council

Supply name: Bunclody Supply code: 3300PUB1425

Population served: 1250 Population affected: 1250

Sample date: 24/04/2012 Sample location: Redmond shop, Bunclody

Notification under regulations: 10(2)

Has the HSE been consulted: Yes

HSE contact: John Redmond HSE contact number: 087 6297110

Advice from HSE: Examine efficiency of treatment process as per Protocol. This should be done in conjunction with investigation into low chlorine and high aluminium levels in the treated water. It is noted that results of raw water monitoring for cryptosporidium are clear to date.

Boil notice:

Date issued: None Date rescinded: None

Boil Notice Parameter: None Boil Notice Precautionary: No

Advisory notice:

Date issued: None Date rescinded: None

Advisory Notice Parameter: None Advisory Notice Precautionary: No

Likely causes: Awaiting Council Investigations

Additional Info. Two cryptosporidium results taken at Bunclody WTW on April 18 and MArch 29th are clear. Awaiting result on third crypto sample taken post exceedence. Also awaiting retest for Clostridiums

Immediate action taken to inform/protect consumers: n/a

Immediate corrective action taken: Reviewing chlorine levels at plant
Note: Contact time unknown, but relevant field would not allow the word unknown to be entered

Notification date: 03/05/2012

Name: Mr. Paul Delahunty

Email: paul.delahunty@wexfordcoco.ie Phone number: 053 9135046

Parameter	Units	Result	Exceeded In Last 12 Months	Chlorine Levels	Recent Details of Raw Water	Chlorine Monitor Alarm	Chlorine Dosing	Flow Dosing	Dosing linked to Chlorine Residual	Contact Time
Clostridium Perfringens	per 100ml	2	False	Sample level of total chlorine 0.05, Free chlorine 0.03	recent rain in river	True	True	True	False	15